

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 536 / प्रयोगशाला (रूर) / 29 Dated: 16/04/2025

It is certified that an inspection team headed by **Sunil Kumar Junior Engineer**

(Name of Officers with designation) from **U.P. Jal Nigam (Rural) Etah PHED**

inspected the **Tulip Public School Etah**

(Name & Address of the school) on **09 April 2025** (date of inspection) and on the basis of Water Test Report

(Attached) bearing no **U2587847S28226298** date **08 April 2025** of **District Level Water Analysis**

Laboratory U.P. Jal Nigam (Rural) Etah (PHED Lab) certified that the **Tulip Public School Etah** (Name

of school) has safe drinking water facilities for the students and members of staff of the institution.

This certificate is valid till **31-03-2026**

Signature with Seal

Name **Vishwjeet** अधिशासी / अभियंता

Designation **Executive Engineer** खण्ड कार्यालय

Name & Address of the Office / Department

U.P. Jal Nigam (Rural) Etah

To

Tulip Public School Etah

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



Jal Jeevan Mission

Har Ghar Jal



Har Ghar Jal
Jal Jeevan Mission

District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), Etah

Office of Executive Engineer, Construction unit, U.P Jal Nigam, Nehru Nagar, Shashtripuram, GT Road, Etah. Pin- 207001 (Test Address only)

Print

Test report

Certificate number:

Certificate number

Sample
Id:

U2587847528226298

User Information

Name:

Tulip public school

Mobile:

7017860172

Email:

STUDENTTULIP@GMAIL.COM

Pin
Code:

207001

Full
Address:

Village- Choncha Bangaon , Gram Panchayat- Choncha Bangaon, Block- Shitalpur, District- Etah, State- Uttar Pradesh

Sample description

Source
of
Sample:

SAMMAR

Village:

Choncha Bangaon

Gram
Panchayat:

Choncha Bangaon

Block:

Shitalpur

District:

Etah

State:

Uttar Pradesh

Address:

Remarks:

DRINKING WATER

Latitude:

Longitude:

Date & time of sample collection

07.04.2025 | 01:59:00 PM

Date & time of sample received in lab

07.04.2025 | 05:43:00 PM

Date & time of sample analysed

08.04.2025 | 05:47:00 PM

Date & time of report generation

1

Test results

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	38.000	EDTA Titrimetric method	
2	Chloride (as Cl)*	mg/l	250	1000	40.000	Argentometric method	
3	Colour*	Hazen units	5	15	5.000	Spectrophotometric method	
4	Fluoride (as F)*	mg/l	1	1.5	0.500	Ion selective electrode method	
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.010	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
6	Magnesium (As Mg)*	mg/l	30	100	30.000	Calculation by APHA	
7	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	0.980	UV-Visible Spectrophotometer	
8	pH*	NA	6.5-8.5	No Relaxation	7.020	Electrometric method	
9	Sulphate (as SO ₄)*	mg/l	200	400	22.000	Turbidimetric method	
10	TDS*	mg/l	500	2000	280.000	Gravimetric method	
11	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	30.000	Titration method	
12	Total Hardness (As CaCO ₃)*	mg/l	200	600	68.000	EDTA Titrimetric method	
13	Turbidity*	NTU	1	5	1.130	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report
- 5)This is not final approved report

Data prepared by
Chemist: (IMRAN ALI)



Authorised signatory
Avneesh Kumar Sharma (Test Lab Incharge)